

Addendum to Appendix B Questions and Answers

Question: Should the blockage investigation fee be included under the 5 year rate on the bid form, or should it be a separate line item?

Answer: Please include the rate in the 5 year amount. If additional services are required, arrangements will be made on a Purchase Order.

Question: If a sprinkler head is dirty/loaded, will we be required to clean it?

Answer: If a sprinkler head is identified as being "loaded", then NFPA requires the head to be replaced, therefore the vendor would not be required to clean.
